



# South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178  
(909) 396-2000 • [www.aqmd.gov](http://www.aqmd.gov)

SENT VIA USPS AND E-MAIL:  
[Jason.Chan@lacity.org](mailto:Jason.Chan@lacity.org)

September 26, 2014

Mr. Jason Chan, Planning Assistant  
City of Los Angeles, City Hall  
Department of City Planning  
200 N. Spring Street, Room 750  
Los Angeles, CA 90012

**Draft Mitigated Negative Declaration (Draft MND) for the Proposed Construction, Use and Maintenance of a Wireless Telecommunications Facility Project at 2300 S. Purdue Avenue in West Los Angeles (NG-14-322-PL; ENV-2014-1902)**

The South Coast Air Quality Management District (SCAQMD) staff appreciates the opportunity to comment on the above-mentioned document both as a commenting agency and a responsible agency. The following comments are meant as guidance for the Lead Agency and should be incorporated into the Final Mitigated Negative Declaration.

In the project description, the lead agency proposes to install, operate and maintain a new, rooftop wireless telecommunications facility. Included in the project description is a new emergency generator with ground level fuel storage. If the proposed generator is diesel-fueled and is rated greater than 50 brake horsepower (bhp), a permit would be required in accordance with SCAQMD rules including Rule 1470 – Requirements for Stationary Diesel-Fueled Internal Combustion and Other Compression Initial Engines and Rule 1110.2 – Emissions From Gaseous- and Liquid-Fueled Engines. If there are permit questions concerning the generator, they can be directed to Engineering and Compliance Staff at (909) 396-2315.


Please provide the SCAQMD with written responses to all comments contained herein prior to the adoption of the Final MND. The SCAQMD staff is available to work with the Lead Agency to address these issues and any other air quality questions that may arise. Please contact Gordon Mize, Air Quality Specialist – CEQA Section, at (909) 396-3302, if you have any questions regarding these comments.

Mr. Jason Chan,  
Planning Assistant

1

September 26, 2014

Sincerely,

A handwritten signature in cursive script that reads "Edward Eckerle".

Edward A. Eckerle  
Program Supervisor  
Planning, Rule Development & Area Sources

EE:RC:GM

LAC140918-06  
Control Number