



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

SENT VIA USPS:

February 12, 2015

Megan Irwin, Senior Planner
City of Highland, Planning Department
27215 Base Line
Highland, CA 92346

Categorical Exemption for CUP-14-003 – Wireless Communication Facility

The South Coast Air Quality Management District (SCAQMD) staff appreciates the opportunity to comment on the above-mentioned project both as a commenting agency and a responsible agency. The following comments are meant as guidance for the Lead Agency.

In the project description, the Lead Agency proposes to install, operate and maintain a new 60-foot tall monopalm wireless telecommunications facility comprised of 12 panel antennas and the construction of a new 225 square foot equipment enclosure. If the proposed project includes a diesel-fueled generator which is rated greater than 50 brake horsepower (bhp), a permit would be required in accordance with SCAQMD rules including Rule 1470 – Requirements for Stationary Diesel-Fueled Internal Combustion and Other Compression Initial Engines and Rule 1110.2 – Emissions From Gaseous- and Liquid-Fueled Engines. If there are permit questions concerning the generator, they can be directed to Engineering and Compliance Staff at (909) 396-2315.

SCAQMD staff is available to work with the Lead Agency to address these issues and any other air quality questions that may arise. If you have any questions regarding this letter, please contact me at jwong@aqmd.gov or call me at (909) 396-3176.

Sincerely,

Jillian Wong

Jillian Wong, Ph.D.
Program Supervisor
Planning, Rule Development & Area Sources

SBC150210-07
Control Number