



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178

(909) 396-2000 • www.aqmd.gov

SENT VIA USPS:

January 2, 2015

Mr. Jason Chan, City Planner
City of Los Angeles, City Hall
Department of City Planning
200 N. Spring Street, Room 750
Los Angeles, CA 90012

Draft Mitigated Negative Declaration (Draft MND) for the Proposed Installation, Use and Maintenance of a Wireless Telecommunications Facility Project at 4806 S. Arlington Ave.; West Adams-Baldwin Hills-Leimert (NG-14-459-PL; ENV-2014-3373)

The South Coast Air Quality Management District (SCAQMD) staff appreciates the opportunity to comment on the above-mentioned document both as a commenting agency and a responsible agency. The following comments are meant as guidance for the Lead Agency and should be incorporated into the Final Mitigated Negative Declaration.

In the project description, the Lead Agency proposes to install, use, and maintain an unmanned wireless telecommunications facility consisting of a freestanding 50-foot tall monopine with 12 panel antennas, 12 remote radio units, two raycaps, and one microwave antenna, with equipment cabinets and one backup power generator at ground level to be screened by an 6-foot fence/solid masonry wall and new landscaping, all located on a 6,100 square-foot lot. If the proposed project includes a diesel-fueled generator which is rated greater than 50 brake horsepower (bhp), a permit would be required in accordance with SCAQMD rules including Rule 1470 – Requirements for Stationary Diesel-Fueled Internal Combustion and Other Compression Initial Engines and Rule 1110.2 – Emissions From Gaseous- and Liquid-Fueled Engines. If there are permit questions concerning the generator, they can be directed to Engineering and Compliance Staff at (909) 396-2315.

Please provide the SCAQMD with written responses to all comments contained herein prior to the adoption of the Final MND. SCAQMD staff is available to work with the Lead Agency to address these issues and any other air quality questions that may arise. If you have any questions regarding this letter, please contact me at jbaker@aqmd.gov or call me at (909) 396-3176.

Sincerely,

Jillian Baker

Jillian Baker, Ph.D.

Program Supervisor

Planning, Rule Development & Area Sources

LAC141225-06
Control Number