



# South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178  
(909) 396-2000 • [www.aqmd.gov](http://www.aqmd.gov)

SENT VIA USPS:

March 10, 2015

Ms. Lupita Garcia, City Planner  
City of Corona, Community Development Department  
400 S. Vicentia Avenue,  
Corona, CA 92882

**CUP15-004 – Application for a 55 foot high, three-leg church tower for wireless communications facilities**

The South Coast Air Quality Management District (SCAQMD) staff appreciates the opportunity to comment on the above-mentioned project. The following comments are meant as guidance for the Lead Agency.

In the project description, the Lead Agency proposes to install, operate and maintain a new 55-foot high, three-leg church steeple tower in the parking lot of the Church parcel. The tower will accommodate 12 panel antennas, 1 MW dish, 3 raycaps, and 12 remote radio units. If the proposed project includes a diesel-fueled generator which is rated greater than 50 brake horsepower (bhp), a permit would be required in accordance with SCAQMD rules including Rule 1470 – Requirements for Stationary Diesel-Fueled Internal Combustion and Other Compression Initial Engines and Rule 1110.2 – Emissions From Gaseous- and Liquid-Fueled Engines. If there are permit questions concerning the generator, they can be directed to Engineering and Compliance Staff at (909) 396-2315.

Please provide the SCAQMD with written responses to all comments contained herein prior to the adoption of the Final MND. SCAQMD staff is available to work with the Lead Agency to address these issues and any other air quality questions that may arise. If you have any questions regarding this letter, please contact me at [jwong1@aqmd.gov](mailto:jwong1@aqmd.gov) or call me at (909) 396-3176.

Sincerely,

*Jillian Wong*

Jillian Wong, Ph.D.  
Program Supervisor  
Planning, Rule Development & Area Sources

RVC150303-04  
Control Number