



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

SENT VIA E-MAIL AND USPS:
jyom@parks.lacounty.gov

August 3, 2016

Julie Yom, Park Planner
County of Los Angeles – Department of Parks and Recreation
510 South Vermont Ave.,
Los Angeles, CA 90020

Draft Environmental Impact Report for the Proposed Puente Hills Landfill Park Master Plan

The South Coast Air Quality Management District (SCAQMD) staff appreciates the opportunity to comment on the above-mentioned document. The following comments are intended to provide guidance to the lead agency and should be incorporated into the Final Environmental Impact Report (EIR) as appropriate.

The proposed project includes a trail lift system to transport guests to the peak of the park. If an emergency generator rated greater than 50 brake horsepower (bhp) is necessary, a permit from SCAQMD would be required and the SCAQMD should be identified as a CEQA responsible agency for this project. The Final EIR should also demonstrate compliance with SCAQMD Rule 201 – Permit to Construct, Rule 203 – Permit to Operate, Rule 1470 – Requirements for Stationary Diesel-Fueled Internal Combustion Engines, and 1110.2 – Emissions From Gaseous- and Liquid-Fueled Engines. If there are permit questions concerning the generator, they can be directed to Engineering and Compliance Staff at (909) 396-2315.

The SCAQMD staff is available to work with the Lead Agency to address these concerns and any other air quality questions that may arise. Please contact Jack Cheng, Air Quality Specialist at (909) 396-2448, if you have any questions regarding these comments. We look forward to reviewing and providing comments for the Final EIR associated with this project.

Sincerely

Jillian Wong

Jillian Wong Ph.D.
Planning & Rules Manager
Planning, Rule Development & Area Sources

JW:JC
LAC 160617-03
Control Number