



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

SENT VIA USPS AND E-MAIL:

April 14, 2017

kwhite@lusd.sbcounty.gov

Kevin White, Senior Planner
Planning Division of the Land Use Services Department
County of San Bernardino
385 North Arrowhead Avenue, First Floor
San Bernardino, CA 92415-0187

Laser Radio Broadcasting Facility (P201000215)

The South Coast Air Quality Management District (SCAQMD) staff appreciates the opportunity to comment on the above-mentioned facility.

The proposed facility consists of a free-standing 43-foot tall monopole and a 100-square-foot equipment shelter on 38.12 acres in the community of Oak Glen of the San Bernardino County. In the event that the proposed facility includes a diesel-fueled generator which is rated greater than 50 brake horsepower (bhp), a permit would be required in accordance with SCAQMD rules, including Rule 1470 – Requirements for Stationary Diesel-Fueled Internal Combustion and Other Compression Initial Engines and Rule 1110.2 – Emissions From Gaseous- and Liquid-Fueled Engines. If there are permit questions concerning the generator, they can be directed to the SCAQMD's Engineering and Compliance staff at (909) 396-2315. In the event that the diesel-fueled generator is in proximity to sensitive receptors, the SCAQMD staff recommends that the Lead Agency evaluate, quantify, and perform a health risk assessment.

SCAQMD staff is available to work with the Lead Agency to address these issues and any other air quality questions that may arise. If you have any questions regarding this letter, please contact me at lsun@aqmd.gov or call me at (909) 396-3308.

Sincerely,

Lijin Sun

Lijin Sun, J.D
Program Supervisor, CEQA IGR
Planning, Rule Development & Area Sources

LS
SBC170411-05
Control Number